



PROMOD Economic Analysis

Latest Results & New Case Study

September 1, 2004


Chris Hagman

Transmission Planning Engineer





Introduction

- Alternatives studied with PROMOD:
 - Base Case
 - Base Case Plus Two Fixes (to relieve the 2 most limiting constraints).
 - South: Byron-North Madison
 - Southwest: Salem-North Madison
 - West: Adams-Columbia
 - West: Prairie Island-Columbia (New)
 - Base Case Plus 3 Low Voltage Tie Lines (New)



New transmission lines shown are for illustrative purposes only. They do not necessarily depict proposed routes.

Key	
	Existing 345 kV - Year 2012
	Representative Project 345 kV

Line Key	
1	- Byron-N Monroe-W Middleton-N Madison
2	- Salem-Spring Green-W Middleton-N Madison
3	- Adams-Genoa-Columbia
4	- Sault Ste. Marie-Arnold
5	- Ludington-Forest Junction
6	- Prairie Island-North La Crosse-Columbia



Introduction

- Have come a long ways...
 - June 2nd
 - Intro to PROMOD & cost analysis methodology
 - Analyzed the reasonableness of tie line flows
 - Started looking at flowgates and shadow prices
 - Iterative process



Introduction

- July 7th
 - Biggest bang for buck
 - Comparison between “production cost” savings and capital costs
 - Fixes:
 - Base Case setup, load mapping–CWL error and WPPI update, etc.
 - Case study:
 - High shadow price–North Monroe 138/69 kV transformer
 - Second transformer (~\$1 million) saves about \$10 million per year for Byron-NMA
 - Scenario:
 - Low internal generation
 - LOLE:
 - Base Case-sufficient import capability to meet LOLE



Introduction

- August 3rd
 - All directions studied
 - East and Northeast alternatives—highest costs & least benefits—dropped by consensus
 - More Fixes/Updates:
 - Added 5 short transmission lines in Illinois to provide generator outlets, additional flowgates
 - Case study:
 - High shadow price on West Middleton-Blackhawk 69 kV cable
 - Relieved by North Madison-Blount 138 kV reliability project
 - Additional benefit—lower LMPs in downtown Madison
 - Scenarios:
 - High wind development, low & high internal generation



Introduction

- September 1st
 - Customer-supplied generator data updates
 - EIA 860 “emergency” capacities can be higher than normal capacities
 - Transmission topology updates in PROMOD:
 - Rockdale-West Middleton 345 kV project
 - Upper Peninsula of MI model updates and corrections
 - Arrowhead-Weston 345 kV reactive requirements
 - NSP/DPC North La Crosse 161 kV project
 - Prairie Island-Columbia & Base Case Plus 3 Low Voltage Ties
 - LMP discussion—reduction in LMP spreads
 - Case study:
 - LMP drivers
 - Scenarios:
 - Low & high natural gas costs



Latest Baseline Results

- Compare the carrying costs for each alternative to the “production cost” savings from PROMOD.


Costs for each Representative Project–Baseline Results

Project	Total Capital Costs (2003\$ Mil.)	Approximate Annual Carrying Cost (2003\$ Mil.)	“Production Cost” Savings Relative to the Base Case¹ (2003\$ Mil.)	Net Imports Relative to the Base Case (GWH)
Base Case	\$0	N/A	0	0
Base Case Plus 2 Fixes	\$30	\$2.7	\$6.9 (+\$0.6)	381 (-232)
South: Byron–NMA	\$143	\$12.9	\$37.1 (+\$22.0)	4,107 (+2,827)
Southwest: Salem–NMA	\$223	\$20.1	\$33.6 (+\$16.9)	3,962 (+2,909)
West: Prairie Island–Columbia ²	> \$244	> \$22.0	\$8.5	585
Base Case Plus 3 LV Ties	?	?	\$14.7	934

¹ The values in parentheses show the change in results relative to the August 3rd Baseline results, e.g. the production cost savings for the “Base Case Plus 2 Fixes” increased by \$0.6 million relative to the previous results.

² Prairie Island-North La Crosse-Columbia is a longer distance than Adams–Genoa-Columbia so the cost of Prairie Island-Columbia would likely be somewhat higher than that for Adams-Columbia.

Base Case Plus 3 Low Voltage Ties





Base Case Plus 3 Low Voltage Ties

Facilities

IL Border WEST - Galena-Hillman 138kV (33 mi.) with 161/138kV.

IL Border CENTRAL - Paddock-N.Monroe-Verona (66 mi.) 69 to 138kV conversion, and additional 345/138 at Paddock

IL Border EAST - McHenry (IL)-Katzenburg 138kV (13 mi.) with additional 345/138 at Pleasant Valley (IL), 69 to 138kV conversion of Katzenburg-N.Lk Geneva (13.8 mi), and Twin Lk-Burlington 138kV (13 mi.)

Stages/Expansion: Projects can be phased and expanded to further include NOM-Lancaster (IL) 138kV, and second line north to Madison (Bass Cr-Verona-WMD?)

Benefits

Parallels Lore-Turkey River-Cassville-NED limits. Project is complimented with TYA plan for Hilman-Eden 138kV.

Paddock-Brodhead 69kV (15.7 mi) already built for 138kV. The project will add voltage support to N. Monroe vicinity, and adds source diversity to west Madison. Project is complimented by TYA plan for a Verona-Cross Country 138kV line and 138/69 transformer.

Adds 2 new ties to IL. McHenry lines have a SE rating of 383 MVA, additional transformers will provide 138kV push, especially under 345kV contingencies. Project is complimented with TYA plan for Paris-Spring Valley-Katzenburg 138kV and Tichigan-St Martins 138kV. Tie line effects further enhanced with Twin Lake-Burlington 138kV and 69 to 138 conversion of Katzenburg-N. lake Geneva.

Various project parts may be implemented on a more expedited time schedule.




LMP Values

- How do the average load-weighted Locational Marginal Prices (LMPs) vary amongst the various transmission alternatives?
- How do these LMP values differ amongst the control areas?
- ALTE and MGE have the highest LMP values in the Base Case.
- How would you expect Byron-NMA and Salem-NMA to affect these values?
- Comparability



LMP Values, Cont.


Average Load-Weighted LMP Values by Control Area for the Various Alternatives for 2012





Case Study

BaseCase Load-Weighted and Generator-Weighted LMPs for ATC for 5:00 PM for 2012






Case Study, Cont.

- Observations:
 - Load-weighted LMPs greater than generator-weighted LMPs
 - Differ by congestion and loss components of the LMP
 - Nearly identical values during low load periods



Case Study, Cont.

BaseCase Load-Weighted LMPs for 5:00 PM for 2012 by Control Area





Case Study, Cont.

- What is causing the load-weighted LMP values for the control areas, and especially WPS, to spike on 7/31/12 at 5 PM?
 - Is the load high?
 - Are there key generator outages?
 - Are there transmission outages?



Case Study, Cont.

- July 31, 2012 at 5:00 PM
 - WPS is at its peak load
 - ATC system is very close to its peak
 - ~ 800 MW of generation within the ATC footprint forced off-line (based on gen. forced outage rates)
 - ~ 350 MW of generation in/near the WPS control area forced off-line
 - Pulliam 4 and 7
 - Fox Energy
 - Total generation within ATC footprint reduced somewhat based on customer capacity updates



Sensitivity Analyses

Natural Gas Scenarios-Production Cost Savings Relative to the Base Case

Project	Baseline “Production Cost” Savings Relative to the Corresponding Base Case (2003\$ Mil.)	10% Decrease in Natural Gas Prices- “Production Cost” Savings Relative to the Corresponding Base Case (2003\$ Mil.)	20% Increase in Natural Gas Prices- “Production Cost” Savings Relative to the Corresponding Base Case (2003\$ Mil.)
Base Case	0	0	0
South: Byron–NMA	\$37.1	\$36.5	\$55.4

- Cost savings for Byron-NMA does not change much for the “10% Decrease in Natural Gas” scenario relative to the “Baseline”.
- Cost savings for Byron-NMA increases by \$18.3 million for the “20% Increase in Natural Gas” scenario relative to the “Baseline”.



What's Next?

- Agree on a reduced list of alternatives for further analysis.
- Refine capital cost data for the remaining alternatives.
- Review geographic distribution of LMP values using MapAgent.