



NERC Alert FAC-008 & FAC-009

Recommendation to Consider Field Conditions When Rating Overhead Lines

Andy Dolan
ATC Customer Meeting
April 25, 2012

Helping to **keep the lights on**,
businesses running and communities strong®





NERC Recommendation to Industry

- Ratings methodology considers field conditions (actual clearances)
- Review facility ratings to field conditions
- Report to NERC



Alert Recommended Actions

- Complete questionnaire January 18, 2011
- Rank facilities
- Review facility ratings to field conditions
 - High priority by 12/31/2011 **Completed**
 - Medium priority by 12/31/2012 **In Progress**
 - Low priority by 12/31/2013 **In Progress**
- Develop a plan to ensure long term that field conditions match design

Issues and Discrepancies

- “Remediation to correct all issues identified during the assessment should occur as quickly as practical but within one year of identification OR obtain approval from NERC to extend deadline.”
- Reporting of discrepancies
 - Report issues resulting in a de rate = discrepancy
 - Report issues
 - At end of 3-year period, enforcement will review response to alert and action taken in determining penalties

How Can You Help

- Timely coordination of efforts to correct clearance issues to distribution facilities
- Ensure encroachment process is followed for distribution facilities crossing and parallel to ATC's facilities
- PSC 114.234A4
 - “Supply lines designed to operate at voltages in excess of 35 kV shall not be constructed over dwellings or mobile homes intended for residential occupancy and dwellings or mobile homes intended for residential occupancy shall not be located under such lines.”
 - Electric utilities are prohibited by s.101.865 from extending electric service to premises which are not in compliance with the Wisconsin State Electrical Code



Questions?

Andy Dolan
Manager - Asset Planning & Engineering
adolan@atcllc.com