



ATC PLANNING UPDATE

Zone 2 Transmission Business Briefing November 7, 2006

Brett French
Senior Regional Manager
Customer Relations

Steve Feak
Principal Engineer
ATC Planning Zone 2



Planning Topics


- **10 Year Assessment**
 - Zone 2 Update

- **Eastern Upper Peninsula**
 - Asset Renewal
 - Local Load Serving
 - Loop Flow



10 Year Assessment


- **ATC Planning processes are:**
 - Continuous
 - Iterative
 - Transparent
 - Effectively performed at “Regional & Local” levels
- **Annual Report posted in Fall**
 - Full Report Posted on ATC Website November 8th
 - www.atcillc.com
 - Zone 2 Summary (see handout)
- **Update posted in Spring**



ATC at a glance

- Formed in 2001 as the first multi-state, **transmission-only utility**.
- Owner and operator of approximately **8,900 miles of transmission line** and **460 substations**.
- Meeting electric needs of approximately **five million people**.
- Transmission facilities in **66 counties** in Wisconsin, Michigan and Illinois.
- **\$1.3 billion** in total assets.
- **Seven offices** in the communities of Cottage Grove, De Pere, Madison, Waukesha and Wausau, Wis.; Kingsford, Mich.; and Washington DC.

System Limitations



System Limitations

- Low voltages
- Overloaded facility
- New generation/stability
- Transmission needed for load growth
- Transmission service limiter



ATC Project Categories


| Planned | Proposed | Provisional |
|--|---|--|
| Studies complete | Studies not complete | Studies not complete |
| Application pending or issued | None | None |
| Project in construction planning phase or under construction | Project identified as preferred alternative | Placeholder project; not necessarily a preferred project alternative |



Zone 2 Summary Projects

| | Project description | In-service year | Need driver |
|---|--|-----------------|--|
| | Planned projects | | |
| 1 | Stiles-Amberg double-circuit 138-kV line rebuild | 2006 | Improves reliability, helps increase import capability, reduces reliance on operating guides, lowers system losses |
| 2 | Cranberry-Conover 115-kV line and Conover-Iron River-Plains rebuild & conversion to 138 kV | 2008 | Part of Cranberry-Conover project (Zone 1) for Rhinelander Loop, improves voltage profile in the area, addresses aging facilities with condition issues |
| | Proposed projects | | |
| 3 | Relocate Cedar Substation (North Lake) | 2008 | Improves reliability in the area, addresses aging facilities in poor condition |
| 4 | Hiawatha-Pine River 69-kV line rebuild & conversion to 138 kV | 2009 | Addresses potential overloads of existing lines in the area, addresses aging facilities in poor condition, improves voltage profile in the area, accommodates future expansion in the area |
| | Provisional projects | | |
| 5 | Convert Hiawatha-Indian Lake double-circuit 69-kV line to 138-kV operation | TBD | Addresses chronic transmission service limitation, improves voltage profiles in the area, enhances value of another provisional project |
| 6 | Replace the existing Straits Substation (Mackinac) | TBD | Improves reliability in eastern UP, addresses substation facilities in poor condition, provides for future expansion |
| 7 | Blaney Park-Munising 69-kV line rebuild & conversion to 138 kV | 2012 | Addresses low voltages in the area, improves stability of Presque Isle generation, addresses aging facilities in poor condition |

System Solutions



System Solutions

| | | | |
|------------|--------------------------|-------------------------|---|
| SS | New substation | Red line | 345-kV transmission line |
| SM | Substation modifications | Blue line | 115-, 138- or 161-kV transmission line |
| PS | Phase shifter | Dark blue line | Rebuilt 115- or 138kV transmission line |
| T | Transformer | Purple line | Transmission line voltage conversion |
| C | Capacitor bank | Green line | 69-kV transmission line |
| R | Reactor | Light green line | Rebuilt 69-kV transmission line |
| T-I | T-D interconnection | | |



Eastern U. P. Issues

- **Asset Renewal (Age & Condition)**
 - Pine River Substation
 - Hiawatha – Pine River 69 kV circuit
- **Local Load Serving (low voltage & overloads)**
 - Case 1: Loss of Hiawatha – Straits 138 kV circuit
 - Case 2: Loss of Straits – McGulpin circuits
 - Loss of ESE hydro output (anchor ice)
 - High Voltage at Straits
- **Loop Flow (voltage & overloads)**
 - Case 3: Heavy West >> East flow
 - Case 4: System Split due to Heavy Flow



Loss of Hiawatha – Straits Circuit

ISSUES:

- Marginal Eastern U.P. system voltages (pre-contingency)
- Unacceptable voltages for loss of Hiawatha – Straits circuit
- Voltage issues exacerbated by heavy East >> West flows
- System split to manage heavy East >> West flow

SOLUTIONS:

- Improved performance with the addition of:
 - Capacitors at Perkins, Indian Lake and Hiawatha substations
 - Construction of 138 kV substation at Hiawatha
 - Indian Lake – Hiawatha double circuit operated at 138 kV
- Splitting of system may still be required to manage heavy flows



Loss of Hiawatha – Straits Circuit

- **Segment 1:**
 - 2013 System Peak – no solutions applied
 - Marginal Eastern U.P. voltages
 - Outage of Hiawatha – Straits 138 kV circuit = **inadequate voltages**
- **Segment 2:**
 - Add H-IL double circuit 138 kV & Hiawatha 138 kV substation
 - Marginal Eastern U.P. voltages
 - Outage of Hiawatha – Straits 138 kV circuit = **marginal voltages**
- **Segment 3:**
 - Add 138 kV capacitors at Perkins, Indian Lake and Hiawatha
 - Marginal Eastern U.P. voltages
 - Outage of Hiawatha – Straits 138 kV circuit = **marginal voltages**
- **Segment 4:**
 - Add 138 kV capacitors, H – IL double circuit 138 kV & Hiawatha 138 kV SS
 - Acceptable Eastern U.P. voltages
 - Outage of Hiawatha – Straits 138 kV circuit = **acceptable voltages**



Loss of Straits – McGulpin Circuits

ISSUES:

- Voltage collapse occurs in Eastern U.P. for loss of both circuits
- Increased exposure risk when one circuit has been removed from service for repair/maintenance (late summer/fall 2006)
- Loss of both circuits has not occurred to date

SOLUTIONS:

- Improved performance with the addition of:
 - Capacitors at Perkins, Indian Lake and Hiawatha substations
 - Construction of 138 kV substation at Hiawatha
 - Indian Lake – Hiawatha double circuit operated at 138 kV



Loss of Straits – McGulpin Circuits

- **Segment 1:**
 - 2013 System Peak – no solutions applied
 - Outage of Straits – McGulpin circuits = **SYSTEM COLLAPSE**
- **Segment 2:**
 - Add H-IL double circuit 138 kV & Hiawatha 138 kV substation
 - Outage of Straits – McGulpin circuits = **inadequate voltages**
- **Segment 3:**
 - Add 138 kV capacitors at Perkins, Indian Lake and Hiawatha
 - Outage of Straits – McGulpin circuits = **inadequate voltages**
- **Segment 4:**
 - Add 138 kV capacitors, H – IL double circuit 138 kV & Hiawatha 138 kV SS
 - Outage of Straits – McGulpin circuits = **acceptable voltages**



ISSUES:

- Inadequate voltages at Perkins and Indian Lake
- Overloaded 138/69 kV Transformer at Indian Lake
- Overloaded Hiawatha – Indian Lake 69 kV circuit 6913
- Transfer Capacity limited to 113 MW at Indian Lake
- System split to manage heavy West >> East flow

SOLUTIONS:

- Improved performance with the addition of:
 - Capacitors at Perkins, Indian Lake and Hiawatha substations
 - Construction of 138 kV substation at Hiawatha
 - Indian Lake – Hiawatha double circuit line operated at 138 kV
- Splitting of system may still be required to manage heavy flows

- **Segment 1:**
 - 2013 System Peak – no solutions applied
 - Imports to LP cause heavy West >> East flow = **inadequate voltages**
- **Segment 2:**
 - Add 138 kV capacitors at Perkins, Indian Lake and Hiawatha
 - West >> East transfer capacity at Indian Lake = **113 MW**
 - Outage of Indian Lake transformer No. 1 = **overload of transformer No. 2**
- **Segment 3:**
 - Add 138 kV capacitors at Perkins, Indian Lake and Hiawatha
 - West >> East transfer capacity at Indian Lake = **113 MW**
 - Outage of H – IL circuit 6912 = **overload of H – IL circuit 6913**
- **Segment 4:**
 - Add 138 kV capacitors, H – IL double circuit 138 kV & Hiawatha 138 kV SS
 - West >> East transfer capacity at Indian Lake = **160 MW**
 - Loss of Hiawatha – Straits 138 kV circuit = **marginally acceptable loading on Pine River – Straits 69 kV circuit**



System Split due to Heavy Flow

ISSUES:

- Inadequate Eastern U.P. voltage for loss of Hiawatha – Straits 138 kV circuit when system is split
- System split to manage heavy West >> East or East >> West flow
- Occurring with increasing regularity and severity due to evolving system conditions

SOLUTIONS:


- Improved performance achieved with the addition of capacitors at Perkins, Indian Lake and Hiawatha substations



Case 4

System Split due to Heavy Flow

- **Segment 1:**
 - 2013 System Peak – no solutions applied
 - Marginal Eastern U. P. voltages
 - Eastern U.P. system split (6912 @ Indian Lake and 6913 @ Hiawatha)
 - Outage of Hiawatha – Straits 138 kV circuit = **inadequate voltages**
- **Segment 2:**
 - Add 138 kV capacitors at Perkins, Indian Lake and Hiawatha
 - Acceptable Eastern U. P. voltages
 - Outage of Hiawatha – Straits 138 kV circuit = **acceptable voltages**





Eastern U. P. Summary

| Project Name | Key Need Drivers | Projected In-Service Date | Projected Cost | Status |
|---|--|------------------------------|----------------|--|
| J: Rebuild Pine River SS | Age & Condition | 3 rd Quarter 2008 | ~ \$5 M | Currently in "Pre-Approval" and Development to define project scope, cost and schedule |
| K: Rebuild Hiawatha – Pine River 69 kV Line | Age & Condition | 2010 | ~ \$60 M | Will start "Pre-Approval" and Development to define project scope, cost and schedule in January 2007 |
| L: 138 kV CAP at Perkins SS | Low system voltages | TBD | TBD | "Proposed" - Studies Complete, Under Review |
| M: 138 kV CAP at Indian Lake SS | Low system voltages | TBD | TBD | "Proposed" - Studies Complete, Under Review |
| N: 138 CAP at Hiawatha SS | Low system voltages | TBD | TBD | "Proposed" - Studies Complete, Under Review |
| O: New Hiawatha 138 kV SS | Required for 138 kV line terminations and installation of 138 kV CAP | TBD | TBD | "Proposed" - Studies Complete, Under Review |
| P: Operate Hiawatha – Indian Lake double circuit at 138 kV | High equipment loadings; low voltages; limited transfer capability | TBD | TBD | "Proposed" - Studies Complete, Under Review |
| Q: New Mackinac 138/69 kV SS, install 138 kV Reactor | High voltage, System Protection, Age & Condition, Reliability | TBD | TBD | "Proposed" - Studies Complete, Under Review |



Management of Heavy Flow

- **Proposed solutions won't resolve all "futures"**
 - Load reductions at Tilden or Empire Mines
 - Unit retirements at Presque Isle Power Plant
 - Increased imports to Lower Peninsula
 - Additional generation proposed at Escanaba
 - New generation proposed at Rogers City
 - Reduced ESE hydro output ("anchor ice" condition)
 - **These "futures" exacerbate heavy flows**

- **Continue to manage flow with "Operational" Solution**
 - **Impact on Customers**
 - MISO Day 2 Market
 - System Losses
 - Reliability
 - Access to Resources

- **Installation of "Flow Control" equipment**
 - Phase Shifter (Approximate cost: ~ \$10 – \$20M)
 - High Voltage DC Control (Approximate cost: ~ \$20+M)
 - Management of flow reduces "system losses"



WRAP-UP

FEEDBACK & QUESTIONS