

Table ES.1: Acceptable Generation Dispatch Schedule

Case	J703 Proposed Testing Net Values (Kuester site)	J704 Proposed Testing Net Values (Mihm site)	PIPP Maximum Allowable Gross Dispatch (at the machine terminals)
1	4 units/52 MW	Off	225MW
2	4 units/68 MW	2 unit/34 MW	225MW
3	7 units/128 MW	Off	225MW
4	3 units/51 MW	3 unit/51 MW	258MW
5	1 units/17 MW	3 unit/55 MW	258MW